

**SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE**


No. DLWTL-March S.No-195/24-25 MDB

Dated: 19/03/2025

It is certified that an inspection team headed by Raman Kumar Jha.Lab.Asst.  
(Name of Officers with designation) from P. H. DIVISION, MADHUBANI (Name  
of Department/Office) inspected the LUTE MILLENNIUM ENGLISH SCHOOL,  
SAKRI, MADHUBANI, BIHAR (Name & Address of the school) on 18/03/2025  
(Date of inspection) and found that the LUTE MILLENNIUM ENGLISH SCHOOL  
(Name of school) has safe drinking water facilities for the students and members  
of staff of the institution and is maintaining the hygienic sanitation condition in the  
school building & the campus as per norms prescribed by the Central/State/ U.T.  
Govt.

The above is valid for a period of One Year

**Principal**  
**L. M. ENGLISH SCHOOL**  
**Sakri, Madhubani (Bihar)**  
07/06/25

Signature with Seal: Name: RAMAN KUMAR JHADesignation: H.E.D. Madhubani

Bihar Govt. Public Health Department (PHED)

Madhubani/ Authprised officer of the local Body

(Name &amp; Address of the Office /Department: )

To

THE DIRECTOR,

LUTE MILLENNIUM ENGLISH SCHOOL,AT + PO- SAKRIMADHUBANI, BIHAR- 847239

**Abhay kr Chandan**  
**7/6/25**  
**Manager**  
**L. M. ENGLISH SCHOOL**  
**Sakri, Madhubani (Bihar)**

# DISTRICT LEVEL WATER TESTING LABORATORY P.H.DIVISION, MADHUBANI

Sample Collected & Submitted by LAB STAFF

Sampling Date:- 18/03/2025

Testing Date:- 19/03/2025

Months:- March 2025

SI No	Block	Panchayat	Village	Source of Water	Name of Location/ Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	SO4	NO3	TDS	EC	AS	Remarks
1	PANDAUL	SAKRI	SAKRI	R.O	LUTE MILLENNIUM ENGLISH SCHOOL	8.02	2.5	44	62	20	7.14	14	0.15	BDL	00	BDL	150	230	NT	
Min-Max-Permissible Limit						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.5 - 1.5	200 - 400	45	500 - 2000		0.01- NR	

\*BDL- Below Detection Limit

\*NT - Not Tested

NOTE:- THIS REPORT IS VALID FOR 6 MONTHS FROM THE DATE OF TESTING.

Principal  
L. M. ENGLISH SCHOOL  
Sakri, Madhubani (Bihar)  
07/06/25

Manager  
L. M. ENGLISH SCHOOL  
Sakri, Madhubani (Bihar)  
Abhay kr.  
7/6/25

CHEMIST  
Lab Assistant/CHEMIST  
District Level Laboratory, Madhubani

19/03/25